

Type test Certificate of complete type tests

Brush Transformers Gulf L.L.C.

Abu Dhabi, United Arab Emirates

has successfully passed the type test sequence on an

Oil-immersed outdoor type power transformer

Type: 15 / 20 MVA

Rating:

15 / 20 MVA – 33 kV + 8 x 1,25% - 12 x 1,25% / 11,5 kV – Dyn 11 – 50 Hz

The test object passed the specification of test duties of

IEC 60076

The test results are recorded in Certificate No.

48-09

This Certificate is issued on 12 June 2009

KEMA Nederland B.V.

A handwritten signature in blue ink, appearing to be "P.G.A. Bus".

P.G.A. Bus
KEMA T&D Testing Services
Managing Director

